



# KERALA GAZETTE കേരള ഗസറ്റ്

PUBLISHED BY AUTHORITY

ആധികാരികമായി പ്രസിദ്ധപ്പെടുത്തുന്നത്

Vol. II വാല്യം 2	THIRUVANANTHAPURAM, TUESDAY തിരുവനന്തപുരം, ചൊവ്വ	15th January 2013 2013 ജനുവരി 15 25th Pousha 1934 1934 പൗഷം 25	No. നമ്പർ	3
---------------------	---	---	--------------	---

## PART III

### Stores Purchase

#### Homoeopathy Department

##### SHORT TENDER NOTICE

No. 3219/A2/2012/GHMCH. 4th December 2012.

Competitive sealed tenders are invited for the supply of Fire Extinguishers for the use of Government Homoeo Medical College Hospital, Karaparamba, Kozhikode.

PAC— 35,000.

EMD— 3,500.

Tenders shall be superscribed as “tender for the supply of Fire Extinguishers” and addressed to the Superintendent, Government Homoeopathic Medical College Hospital, Karaparamba, Calicut-10. The last date for receipt of tender is 24-1-2013 at 11 a. m. Tenders will be opened at 11.30 a. m. on the same day in presence of tenderers or their authorised representatives who may be present at that time.

Those who want tender forms should apply to the Superintendent, Government Homoeo Medical College Hospital, Karaparamba, Calicut-10. Application for tender form should be accompanied by a cash remittance of 800 (inclusive of taxes) which is the price fixed for a form which is not refundable under any circumstances. Sale of tender form will be closed at 3 p.m. on 23-1-2013 (17-1-2012 by post). The tender forms will be obtained

from the Hospital office on direct payment or M. O. only on working days. Those who want tender forms by post should send an additional amount of 50 towards postage charges. Duplicate forms if required will be issued at 400 (inclusive of taxes) per copy.

A Demand Draft for an amount of 1% of the total cost of items should be enclosed along with the tender as EMD. Specification also is to be attached with tender. An agreement in the prescribed form executed and signed in Kerala Government Stamp Paper worth 100 should also be submitted along with tender.

The tender without the required EMD and agreement will be summarily rejected. Late tenders will not be entertained on any account.

Any additional information required can be had from the office of the undersigned during the working hours.

കോഴിക്കോട് ഗവൺമെന്റ് ഹോമിയോപ്പതിക് മെഡിക്കൽ കോളേജ് ആശുപത്രിയിലേക്ക് ഫയർ എക്സ്റ്റിങ്ക്വയ്ക്കർ സപ്ലൈ ചെയ്യുന്നതിന് മത്സരസ്വഭാവമുള്ള ദർഘാസുകൾ ക്ഷണിച്ചു കൊള്ളുന്നു. ദർഘാസു കവറിനുമുകളിൽ “ഫയർ എക്സ്റ്റിങ്ക്വയ്ക്കർ വിതരണം ചെയ്യുന്നതിനുള്ള ദർഘാസു” എന്ന് രേഖപ്പെടുത്തിയിരിക്കേണ്ടതാണ്. ദർഘാസുകൾ 24-1-2013-ന് രാവിലെ 11 മണിക്ക് മുമ്പായി സൂപ്രണ്ട്, ഗവൺമെന്റ് ഹോമിയോ മെഡിക്കൽ കോളേജ് ആശുപത്രി, കാരുപ്പറമ്പ്, കോഴിക്കോട്-10 എന്ന വിലാസത്തിൽ ലഭിച്ചിരിക്കേണ്ടതാണ്. വൈകിലഭിക്കുന്ന ദർഘാസുകൾ

യാതൊരുകാരണ വശാലും പരിഗണിക്കുന്നതല്ല. ലഭിക്കുന്ന ദർഘാസുകൾ അന്നേദിവസം 11.30 മണിക്ക് ദർഘാസ് സമർപ്പിച്ചവരുടേയോ അവർ അധികാരപ്പെടുത്തിയ വ്യക്തിയുടേയോ സാന്നിധ്യത്തിൽ തുറന്നു പരിശോധിക്കുന്നതും ഏറ്റവും കുറഞ്ഞ നിരക്ക് രേഖപ്പെടുത്തിയതുമായ ദർഘാസുകൾ അംഗീകരിക്കുന്നതു മാണ്.

അടങ്കൽ തുക— 3,50,000.

നിരവദ്രവ്യം— 3,500.

ദർഘാസിന്റെ കൂടെ മൊത്തം തുകയുടെ ഒരു ശതമാനം വരുന്ന തുകയ്ക്കുള്ള ഡിമാന്റ് ഡ്രാഫ്റ്റ് നിരവദ്രവ്യമായും കേരള സർക്കാരിന്റെ 100 മുദ്രപത്രത്തിൽ നിശ്ചിത മാതൃകയിലുള്ള സമ്മതപത്രവും ഉള്ളടക്കം ചെയ്യേണ്ടതാണ്.

ദർഘാസുകൾ ആവശ്യമുള്ളവർ സുപ്രണ്ട്, ഗവൺമെന്റ് ഹോമിയോ മെഡിക്കൽ കോളേജ് ആശുപത്രി, കാരപ്പറമ്പ്, കോഴിക്കോട്-10 എന്ന വിലാസത്തിൽ സ്വന്തം പേപ്പറിൽ സമർപ്പിക്കേണ്ടതാണ്. ദർഘാസ് ഫോറത്തിന്റെ വില 800 (നികുതി ഉൾപ്പെടെ) രൂപയാണ്. ഇത് യാതൊരു കാരണവശാലും തിരിച്ചു നൽകുന്നതല്ല. ദർഘാസുകൾ കൈമാറ്റം ചെയ്യുവാൻ പാടുള്ളതല്ല. ടെണ്ടർ ഫോറം തപാലിൽ ലഭിക്കണമെങ്കിൽ 50 തപാൽ ചാർജ്ജായി അയയ്ക്കേണ്ടതാണ്. ഡ്യൂപ്ലിക്കേറ്റ് ഫോറം ആവശ്യമുള്ളവർ 400 (നികുതി ഉൾപ്പെടെ) കൂടുതലായി അയയ്ക്കേണ്ടതാണ്. ദർഘാസ് ഫോറം 23-1-2013, 3 മണിവരെ നേരിട്ടും 17-1-2013, 3 മണിവരെ തപാൽമുഖേനയും ലഭിക്കുന്നതാണ്. തപാൽ മുഖേന ലഭിക്കണമെങ്കിൽ മണിയോർഡർ മാത്രമേ സ്വീകരിക്കുകയുള്ളൂ. വിതരണം ചെയ്യുവാൻ ഉദ്ദേശിക്കുന്ന എയർ കണ്ടീഷണറുടെ വിശദവിവരങ്ങൾ (അളവ്, കമ്പനി മുതലായവ) ദർഘാസിന്റെ കൂടെ അടക്കം ചെയ്യേണ്ടതാണ്.

കൂടുതൽ വിവരങ്ങൾക്ക് പ്രവൃത്തി ദിവസങ്ങളിൽ ആശുപത്രി ഓഫീസിൽ നിന്നും ലഭിക്കുന്നതാണ്.

DETAILS OF ITEMS

Technical Specification of ABC MAP90 6Kg Fire Extinguisher

Sl. No.	Specifications
1	ABC MAP90 (Mono Amonium Phosphate 90)
2	CE Certificate (CE mark encraved Valve)
3	ISI mark (IS:15683)
4	Manufacturer Logo or name should be mentioned on pressure guage
5	Five year warranty certificate from manufacturer

Technical Specification of Clean Agent HFC 4Kg Fire Extinguisher

Sl. No.	Specifications
1	Hydro Floro Carbon Gas
2	CE Certificate (CE mark encraved Valve)
3	ISI mark (IS:15683)
4	Manufacturer Logo or name should be mentioned on pressure guage
5	Five year warranty certificate from manufacturer

Technical Specification of Clean Agent HFC 2kg Fire Extinguisher

Sl. No.	Specifications
1	Hydro Floro Carbon Gas
2	CE Certificate (CE mark encraved Valve)
3	ISI mark (IS:15683)
4	Manufacturer Logo or name should be mentioned on pressure guage
5	Five year warranty certificate from manufacturer

Government Homoeopathic Medical College Hospital, Kozhikode.

(Sd.) Superintendent.